

NEBRASKA ADMINISTRATIVE CODE

TITLE 229 - DEPARTMENT OF LABOR

CHAPTER 4 - GENERAL REQUIREMENTS FOR BOILERS AND PRESSURE VESSELS

001. This chapter is adopted pursuant to *Neb. Rev. Stat.* §48-727.
002. Any required safety appliance shall not be removed or tampered with except for the purpose of repair or inspection.
003. Where pressure reducing valves are used, one or more relief or safety valves shall be provided on the low pressure side of the reducing valve when the piping equipment on the low pressure side does not meet the requirements for the full initial pressure.
004. The relief or safety valves shall be located, adjoining, or as close as possible to the reducing valve. Proper protection shall be provided to prevent injury or damage caused by the escaping fluid from the discharge of relief or safety valves vented to the atmosphere. The combined discharge capacity of the relief valves or safety valves shall be such that the pressure rating of the lower pressure piping shall not be exceeded in case the reducing valve sticks open.
005. If a bypass is used around the reducing valve, a safety valve is required on the low pressure side and shall be of sufficient capacity to relieve all the fluid that can pass through the bypass without over pressuring the low pressure side. A pressure gage shall be installed on the low pressure side of a reducing valve.
006. The blowdown from a boiler that enters a sanitary sewer system or which is considered a hazard to life or property, shall pass through proper blowoff equipment that will reduce pressure and temperature. The temperature of the fluid leaving the blowoff equipment shall not exceed 150 degrees Fahrenheit, and the pressure shall not exceed five pounds per square inch. The blowoff piping and fittings between the boiler and the blowoff tank shall comply with the ASME code.

007. The discharge from safety valves, safety relief valves, blowoff pipes and other outlets shall be so arranged that there will be no danger of scalding personnel. When the safety valve or temperature/pressure relief valve discharge is piped away from the boiler to the point of discharge, there shall be provisions made for properly draining the piping. The size and arrangement of discharge piping shall be such that any pressure that may exist or develop, will not reduce the relieving capacity of the relieving devices below that capacity required to protect the boiler or pressure vessel. Manifolding of discharges from multiple boilers or pressure vessels having different maximum allowable working pressures is not permitted; unless verification including design calculations, and component specification have been approved in advance by the person or entity who will perform the hydrostatic test and certification required in 229 NAC 2, §007.
008. Electric steam generator - a cable at least as large as one of the incoming power lines to the generator shall be permanently fastened to and provide grounding of the generator shell.
- A. A suitable screen or guard shall be provided around high tension bushings and a sign posted warning of high voltage. This screen or guard shall be so located that it will be impossible for anyone working around the generator to accidentally come in contact with the high voltage circuits.
 - B. All electrically heated boilers shall meet the applicable standards of and be approved by Underwriters' Laboratories, Inc.
009. All repairs and alterations must comply with the rules as defined in 229 NAC 15.
- A. All welded repairs shall be done by an organization holding the applicable "R" stamp issued by the National Board, except that in the case of pressure vessels installed at an API-510 owner-user facility, the repair may be done by a repair organization as defined in section 3.16 of API-510. All repairs require prior notification and approval of a commissioned inspector. All repairs shall conform to the latest edition and addenda of the NBIC or API-510 adopted by the state.
 - B. The organization performing the repair or alteration is responsible for preparation and distribution of the appropriate NBIC form or its equivalent under API-510. This report shall be filed with the Department.
010. All boilers and unfired pressure vessels shall be located so that adequate space is provided for the proper operation of the boiler or pressure vessel and its appurtenances, inspection, and necessary maintenance and repair.
011. Ladders and walkways or runways shall be provided between or over the top of boilers which are more than eight feet above the operating floor to afford accessibility for maintenance and inspection.
- A. All walkways, runways, and platforms shall:
 - (1) be of metal construction;
 - (2) be constructed of safety treads, standard grating, or similar material and have a minimum width of 30 inches;
 - (3) be of bolted, welded or riveted construction;

- (4) be equipped with handrails 42 inches high with an intermediate rail and 4 inch toeboard;
 - B. Stairways which serve as a means of access to walkways, runways or platforms shall not exceed an angle of 45 degrees from the horizontal and be equipped with handrails 42 inches high with an intermediate rail.
 - C. Ladders which serve as a means of access to walkways, runways, or platforms shall:
 - (1) be of metal construction and not less than 18 inches wide;
 - (2) have rungs that extend through the side members and are permanently secured;
 - (3) have a clearance of not less than 30 inches from the front of the rungs to the nearest permanent object on the climbing side of the ladder;
 - (4) have a clearance of not less than 6-1/2 inches from the back of the rungs to the nearest permanent object;
 - (5) have a clearance width of at least 15 inches from the center of the ladder on either side across the front of the ladder;
 - D. There shall be at least two permanently installed means of egress from walkways, runways, or platforms that exceed six feet in length.
012. All boiler rooms exceeding five hundred square feet floor area and containing one (1) or more gas fired objects having a fuel burning capacity of four hundred thousand British thermal units shall have two (2) means of exit.
013. A permanent source of outside air shall be provided for each boiler room to permit satisfactory combustion of the fuel as well as proper ventilation of the boiler room under normal operating conditions. The total air input required for all burners installed on the boiler or water heater shall be used in determining the net intake area required. The requirements outlined in the following manuals or codes shall be used to determine the air required.
- A. The boiler or water heater manufacturer's installation and operating manual;
 - B. NFPA-54, National Fuel Gas Code;
 - C. NFPA-85;
 - D. NFPA-58, LP-Gas Code.
014. Condensate return tanks shall be equipped with at least two (2) vents, or a vent and overflow pipe to protect against a loose float plugging a single connection.
015. If a boiler or unfired pressure vessel has not been properly prepared for inspection as defined in 229 NAC 6 and/or requested by the inspector, the inspector may decline to make such inspection until the boiler has been properly prepared and inspected.
016. The applicable code of construction, or the appropriate API, ANSI, or NFPA code shall apply to all conditions not covered by these rules and regulations.

017. Whenever repairs are made to fittings and appliances or it becomes necessary to replace them, the work must comply with the requirements of the applicable construction code, the National Board Inspection Code and API-510 as appropriate for boilers and pressure vessels. For boilers that have control systems that are required to meet the rules of ASME CSD-1, when components of the control systems are repaired or replaced, the replacements and the affected part of the control system must meet the current state adopted edition and addenda of ASME CSD-1. For boilers that have control systems that were required to meet the rules of NFPA 8501, 8502, 8503, 8504, 8505, or 8506, when components of the control systems are repaired or replaced, the replacements and the affected part of the control system must meet the current state adopted edition and addenda of NFPA 85. If a part is replaced with a part that is like for like in make, model and specifications, an upgrade to the latest adopted edition/addenda of the applicable code is not required. If a part is replaced that is not like for like, that section of the control system shall be upgraded to the latest edition/addenda of the applicable code for the controls. When a fuel train is upgraded or replaced, the required emergency shutdown switch(s) shall be installed and the complete fuel train shall meet the latest adopted edition/addenda of the appropriate code. If there are any questions as to the need and extent of the upgrade, a detailed plan shall be submitted to the Chief Boiler Inspector outlining the make, model, and specifications of the component being removed and the make, model and specifications of the intended replacement part and any other necessary information to determine the need for an upgrade. This plan shall include which standards the component or portion of the system is designed and constructed to meet.
018. Special requirements for hydronic (glycol) heating systems.
- A. Systems where there is a possibility of contamination between the potable water system and the heating system shall be protected in accordance with local codes. Where there are no local codes, the International Plumbing and Mechanical Codes should be used as a reference for the protection of the potable water system.
 - B. All boilers supplying the heating system shall have safety controls to protect against a low water condition. The controls shall shut down the boiler and require a manual restart. The controls shall be installed and meet the requirements of ASME CSD-1, Part CW for the specific type of boiler.
 - C. A means shall be provided to refill the hydronic heating system. This means can either fill the system while in operation or require a shutdown prior to filling.
 - D. The discharge from the boiler safety relief valve and the boiler drains shall be piped to an atmospheric collection tank. The ends of the piping shall be visible to determine if a safety relief valve or drain valve is leaking past the seat. Certain types of glycol require a special permit for discharge to a city sewer system.
 - E. Hydronic piping systems shall be designed and installed to permit the system to be drained. Where the system drains to the plumbing drainage system, the installation shall conform to the local codes. Where there are no local codes the International Plumbing and Mechanical Codes should be used as a reference.
 - F. The boiler shall have isolation valves on the inlet and outlet piping.

- G. All boilers used in hydronic heating systems shall meet the requirements of ASME Section IV, Part HG, and be stamped with the ASME "H" Symbol Stamp. Units with the ASME "HLW" Symbol Stamp or items certified as meeting the requirements of ANSI Z21.10.3 shall not be used in hydronic heating systems.
- H. Records shall be maintained and available to the inspector that show the required glycol concentration, the results of all tests performed to ensure the concentration percentage is being maintained and the addition of glycol to the system.

U:\Word\Regulations\229 - Boilers\Revision 2005\Regs & Attachment Forms\Chapter 4\229-04 final.doc